

**TENDER FOR SUPPLY AND INSTALLATION OF AIR HANDLING UNIT –
HVAC AND FILTRATION SYSTEMS TO STERILITY LAB OF DEPT. OF
BIOLOGICAL CONTROL AT KING INSTITUTE OF PREVENTIVE MEDICINE
AND RESEARCH, CHENNAI**

TENDER NO. 585/AHU/KIPM/TNMSC/ENGG/2020, DT: 31.07.2020

Results of Evaluation

Air Handling Unit – HVAC filtration system – 1 No.

Sl. No	Bidders Quoted	Model/ Make	Responsiveness		Reason for rejection / Remarks
			Technical evaluation report	Commercial evaluation report	
1.	M/s. Mark Air Particulate Control Systems, Chennai	Own make	Responsive	Responsive	-----
2.	M/s. Navakar Scientific, Chennai	Own make	Responsive	Responsive	-----
3.	M/s. Eakcon Systems Pvt Ltd, Chennai	Own make	Responsive	Responsive	-----
4.	M/s. Promace Engineering LLP, Chennai	Make: M/s. Bluestar Ltd, Chennai and M/s. Pioneer Coldstore & cladding Pvt. Ltd.	Responsive	Responsive	-----
5.	M/s. Kleanzone Systems	Own make	Non-Responsive	Non - Responsive	1. Model quoted does not meet the following points a. AHU- required Class 100 & Class 1000 cleanliness:

Sl. No	Bidders Quoted	Model/ Make	Responsiveness		Reason for rejection / Remarks
			Technical evaluation report	Commercial evaluation report	
	(India) Pvt. Ltd.				<p>confirmed to supply Class 1000 & Class 10000.</p> <p>b. Pre filers - For particles in the range of 10 microns & 5 Microns – Non – woven fabric, cleanable media with aluminium support mesh; to match AHU capacity – 2 sets (1 for each AHU):- complied to provide Class 1000 and class 10000.</p> <p>c. Separate AHU each of Class 100 is required for alternating: – complied to provide Class 1000.</p> <p>Hence not-recommended</p> <p>2. Despite given chance the bidder did not furnish clarification / documents for the following points:</p> <p>a. Documentary evidence for satisfactory performance of the item quoted, to meet Qualification Criteria</p> <p>b. Not confirmed to warranty terms.</p> <p>c. Not confirmed to spare parts.</p> <p>Hence not recommended</p>